

November 2026 Capstone dates

Design, install and verify compliance and functionality of general electrical installations – UEEEL0039

Monday 8 am – 3:30 pm	Tuesday 8 am – 3:30 pm	Wednesday 8 am – 3:30 pm	Thursday 8 am – 3:30 pm	Friday 8 am – 3:30 pm
12/10/26	All day tutorial 13/10/26	All day tutorial 14/10/26	Deadline to submit assessment items 15/10/26	16/10/26
19/10/26	20/10/26	21/10/26	Deadline to submit committee documentation 22/10/26	23/10/26
Possible date for site visit 26/10/26	Possible date for site visit 27/10/26	Possible date for site visit 28/10/26	Possible date for site visit 29/10/26	Possible date for site visit 30/10/26
Possible date for site visit 02/11/26	Possible date for site visit 03/11/26	Possible date for site visit 04/11/26	Possible date for site visit 05/11/26	Possible date for site visit 06/11/26
09/11/26	10/11/26	11/11/26	12/11/26	ACT Government Industry Reference Committee meeting 13/11/26
16/11/26	Capstone day 1/8 (all-day class) 17/11/26	Capstone day 2/8 (all-day class) 18/11/26	Capstone day 3/8 (all-day class) 19/11/26	20/11/26
23/11/26	Capstone day 4/8 (all-day class) 24/11/26	Capstone day 5/8 (all-day class) 25/11/26	26/11/26	27/11/26
30/11/26	Capstone day 6/8 (theory assessments) 01/12/26	Capstone day 7/8 (theory assessments) 02/12/26	Capstone day 8/8 (Group 1) (prac assessments) 03/12/26	Capstone day 8/8 (Group 2) (prac assessments) 04/12/26
Feedback to assessments (to book after 3:30 pm) 07/12/26	Feedback to assessments (to book after 3:30 pm) 08/12/26	09/12/26	10/12/26	11/12/26
Assessment results (if eligible/required) 14/12/26 3:30 pm	15/12/26	16/12/26	17/12/26	18/12/26
21/12/26	22/12/26	23/12/26	Qualifications may be available 24/12/26	Public Holiday 25/12/26

Note: To attend dates in orange with borders

Note: 8 days total, only one of the last two Practical Assessment days required

Prior to Capstone, please read the following material

Maximum Demand (MD): AS/NZS 3000 > Section 2.2.2 > Appendix C2, C5 > Tables C1 – C7 & C9	Protection Device coordination: AS/NZS 3000 > Section 2.5.1 to 2.5.3 > Section 3.4 > Appendix B3	Cable selection based on Current Carrying Capacity (CCC): AS/NZS 3008 > Section 2.1, 2.2 & 2.3 > Section 3.1 to 3.5 > Table 3(1) – 3(4) > Tables 4 – 21 > Tables 22 – 29 AS/NZS 3000 > Appendix C3	Cable selection based on Voltage Drop (VD): AS/NZS 3000 > Section 3.6 > Section 7.5.7 > Appendix C4 > Table C8 AS/NZS 3008 > Section 4.1 & 4.2 > Tables 1, 40–51	Cable selection based on Fault Loop Impedance (FLI): AS/NZS 3000 > Section 1.5.5.1 to 1.5.5.3 > Section 5.7 > Appendix B4 & B5 > Section 8.3.9
Prospective Fault Current (PFC) (CB/Fuses) and Short Circuit Temperature Rise (SCTR) (Cables): AS/NZS 3000 > Section 2.5.4 AS3008 > Section 5	Earthing: AS/NZS 3000 > Section 5.1, 5.3 to 5.6, > Table 5.1 & 8.2	Testing: AS/NZS 3000 > Section 8	WH&S: How to Manage Work Health and Safety Risks Code of Practice 2020 (Read All) Link here Work Health and Safety Regulations 2011 (Read Division 4) Link here Managing Electrical Risks at the Workplace Code of Practice Approval 2015 (Familiarise with) Link here	